




OVERFILL PROTECTION DEVICE MH61303 CAN/ULC08661-10

Class I Division 1 and 2, Groups A,B,C,D,T5





HOUSING: Nema 4X, Explosion Proof, Class 1, Div 1, Group C & D

MAXIMUM PRESSURE: 150 PSI

OPERATING TEMPERATURE: -20F ~ 250F FLOAT MATERIAL: Stainless Steel

Switch Certified To:

CAN/CSA STD. C22.2 NO. 1010-1

CAN/CSA STD. C22.2 NO. 30

Conforms To:

UL1203 & ANSI/ISA S82-03

FLOAT LEVEL	FL1	ALBANY PUMP CO. LTD.
FUNCTION	Continuous Level	DRWN. 420 HARRY WALKER PARKWAY NEWMARKET, ONT. CANADA L3Y 8P5
HEIGHT FROM TOP OF TANK		scale _{none} FUF O ACCESSORIES
neight from 10P of TANK	Inches	CHK'D I.F.VCON CI.T
OUTPUT TYPE	4-20 mA	This drawing and the information depicted therein is the property of Albany Pump Co. Ltd. Copies are issued in strict confidence and shall not be reproduced, copied or used as the basis for the manufacture or
4-20 mA WIRE COLOUR	BROWN = Signal, BLUE = VDC	sale of products without prior written permission of Albany Pump Co.